

HAZARDOUS SUBSTANCES RISK ASSESSMENT

Designer Contracts Ltd

Unit 8, Church View, Coney Green, Chesterfield, S45 9HA

CPL- Mapei Ecoprim Grip Plus	Date of Assessment : 31/01/2022	Reference : CPL Ecoprim Grip Plus
Risk Assessor : Laura Cross	Risk Assessor :	
Other People Involved in Making This Assessment : Adam Denton		

R or H Descriptors:	S or P Descriptors:
Additional Information	
Workspace Exposure Limit (WEL)	

Primary route(s) of entry : Absorption, Ingestion, Inhalation	
This is a Group Substance.	The quantity used per batch or work period is: Medium (1-1000kg or 1-1000L)
The Substance is a Liquid of Low volatility	
is the control measure appropriate to control the health risks from the use of this substance. Health Surveillance is not required.	

Existing Control Measures
1. Always use in well ventilated area
2. First Aid Measures: In case of skin contact: Wash with plenty of water and soap. In case of eyes contact: Wash immediately with water.
3. In case of Ingestion: Do not induce vomiting, get medical attention showing the SDS and the hazard label. In case of Inhalation: Remove casualty to fresh air and keep warm and at rest.
4. Fire Fighting Measures: Suitable extinguishing media: Water, Carbon dioxide (CO2).
5. Special hazards arising from the substance or mixture Do not inhale explosion and combustion gases. Advice for firefighters Use suitable breathing apparatus.
6. Ensure correct PPE is worn, Gloves
7. Do not allow to enter into soil/subsoil. Do not allow to enter into surface water or drains. Limit leakages with earth or sand.
8. Suitable material for taking up: absorbing material, organic, sand Retain contaminated washing water and dispose it.
9. Avoid contact with skin and eyes, inhalation of vapours and mists.
10. Do not eat or drink while working.
11. Keep away from food, drink and feed.
12. EWC 08 04 14 Always return empty packaging to region and dispose of in Drum B

Documents Associated with this Risk Assessment : Eco Prim Plus Grip SDS.pdf(SDS)

Review Date : 31/01/2023