

HAZARDOUS SUBSTANCES RISK ASSESSMENT

Designer Contracts Ltd

Unit 8, Church View, Coney Green, Chesterfield, S45 9HA

CPL Tilemaster Fast one coat DPM Part B	Date of Assessment : 12/12/2022	Reference : CPL - Tilemaster Fast one coat DPM Part B
Risk Assessor : Laura Cross	Risk Assessor :	
Other People Involved in Making This Assessment : Antony Maidens		



R or H Descriptors:	S or P Descriptors:
H314 Causes severe skin burns and eye damage H317 May cause an allergic skin reaction H335 May cause respiratory irritation H360 May damage fertility or the unborn child H361 Suspected of damaging fertility or the unborn child H411 Toxic to aquatic life with long lasting effects EUH208 Contains <name of sensitising substance>. May produce an allergic reaction.	P102 Keep out of reach of children P260 Do not breathe dust/fume/gas/mist/vapours/spray P280 Wear protective gloves/protective clothing/eye protection/face protection P301 IF SWALLOWED P301+330+331 IF SWALLOWED; Rinse mouth. Do NOT induce vomiting P302+352 IF ON SKIN; Wash with soap and water P303+361+353 IF ON SKIN (or hair); Remove/Take off immediately all contaminated clothing. Rinse skin with water/shower P501 Dispose of contents/container to ...xxxxx

Additional Information
 P501 P501 Dispose of contents/container in accordance with the local waste disposal authority.

Workspace Exposure Limit (WEL)
 Long term 8 hr limit mg/m3 Short Term 15 min limit mg/m3

Primary route(s) of entry : Absorption, Ingestion, Inhalation	
This is a Group D Substance.	The quantity used per batch or work period is: Medium (1-1000kg or 1-1000L)
The Substance is a Liquid of Low volatility	
Containment is the control measure appropriate to control the health risks from the use of this substance. Health Surveillance is not required.	

Existing Control Measures
 1. Always use in well ventilated areas.

2. First Aid Measures: Inhalation, Exposure may cause: Shortness of breath with a burning sensation in the throat. Exposure may cause coughing or wheezing. If breathing is difficult give oxygen. If conscious, ensure the casualty sits or lies down.
3. If unconscious and breathing is OK, place in the recovery position. Remove casualty from exposure ensuring one's own safety whilst doing so. Transfer to hospital as soon as possible.
4. Eye Contact: Exposure may cause: Corneal burns and permanent damage. Bathe the eye with running water for 15 minutes. Transfer to hospital for specialist examination.
5. Skin Contact: Corrosive and Irritant Effects. Blisters. Drench the affected skin with running water for 10 minutes or longer if substance is still on skin. Remove all contaminated clothes and footwear immediately unless stuck to skin. Transfer to hospital if there are burns or symptoms of poisoning.
6. Ingestion: Exposure may cause: Corrosive burns around the lips. There may be bleeding from the mouth or nose. IF SWALLOWED: rinse mouth. Do NOT induce vomiting. If unconscious and breathing is OK, place in the recovery position.
7. If unconscious, check for breathing and apply artificial respiration if necessary. Transfer to hospital as soon as possible.
8. Corrosive. Burning produces irritating, toxic and obnoxious fumes.
9. Do not empty into drains; dispose of this material and its container in a safe way. Contain the spillage using bunding.
10. Absorb with inert, absorbent material. Clean spillage area thoroughly with plenty of water. Transfer to suitable, labelled containers for disposal.
11. Keep only in the original container in a cool, well-ventilated place. Store in original container.
12. EWC code 08 04 09 * Always return empty packaging to region and dispose of in Drum A

Documents Associated with this Risk Assessment : MSDS-FastOneCoatDPMPartB.pdf(SDS)

Review Date : 23/12/2023