

HAZARDOUS SUBSTANCES RISK ASSESSMENT

Designer Contracts Ltd

Unit 8, Church View, Coney Green, Chesterfield, S45 9HA

CPL Stopgap 1100 Gypsum (Fball)	Date of Assessment : 23/05/2023	Reference : CPL - Stopgap 1100 Gypsum (Fball)
Risk Assessor : Laura Cross	Risk Assessor :	
Other People Involved in Making This Assessment : Antony Maidens		

R or H Descriptors:	S or P Descriptors:
Additional Information	
Workspace Exposure Limit (WEL) (8-hour TWA) WEL 10 total dust; 4 respirable dust mg/m ³	

Primary route(s) of entry : Absorption, Ingestion, Inhalation	
This is a Group Substance.	The quantity used per batch or work period is: Medium (1-1000kg or 1-1000L)
The Substance is a Solid of High dustiness	
is the control measure appropriate to control the health risks from the use of this substance. Health Surveillance is not required.	

Existing Control Measures
1. First aid measures General information Remove affected person from source of contamination. Inhalation Move affected person to fresh air at once. Get medical attention if any discomfort continues.
2. Ingestion Rinse mouth thoroughly with water. Give plenty of water to drink. Do not induce vomiting. Get medical attention if any discomfort continues. Skin contact Remove contaminated clothing. Rinse immediately with plenty of water. Get medical attention if any discomfort continues.
3. Eye contact Rinse immediately with plenty of water. Continue to rinse for at least 15 minutes and get medical attention.
4. Suitable extinguishing media The product is non-combustible.
5. Specific hazards Dust may form explosive mixture with air. Hazardous combustion products Does not decompose when used and stored as recommended.
6. Personal precautions Avoid inhalation of dust. Avoid contact with skin and eyes.
7. Environmental precautions Do not discharge into drains or watercourses or onto the ground.
8. Methods for cleaning up Avoid generation and spreading of dust. Remove spillage with vacuum cleaner or collect with a shovel and broom, or similar.
9. Usage precautions Avoid handling which leads to dust formation. Good personal hygiene procedures should be implemented. Do not eat, drink or smoke when using this product.
10. Storage precautions Keep away from food, drink and animal feeding stuffs. Keep container dry.

- | | |
|--------------------------------------|---|
| 11. Appropriate engineering controls | Provide adequate ventilation. Avoid inhalation of dust. Observe any occupational exposure limits for the product or ingredients. |
| 12. Hand protection | Chemical-resistant, impervious gloves complying with an approved standard should be worn if a risk assessment indicates skin contact is possible. |
| 13. Other skin and body protection | Wear appropriate clothing to prevent repeated or prolonged skin contact. |
| 14. Respiratory protection | Respiratory protection must be used if the airborne contamination exceeds the recommended occupational exposure limit. |
| 15. Disposal methods | The generation of waste should be minimised or avoided wherever possible. Collect and place in suitable waste disposal containers and seal securely. Dispose of waste product or used containers in accordance with local regulations Waste Code 16.03.03 |
| 16. Transport information | -The product is not covered by international regulations on the transport of dangerous goods (IMDG, IATA, ADR/RID). |

Documents Associated with this Risk Assessment : Stopgap-1100-Gypsum-iss-4.pdf(Safety Data Sheet) safety.1100-gypsum.en.pdf(SDS)

Review Date : 08/06/2024